



CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Mineral Fiber Block and Board Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

ARABIAN FIBERGLASS INSULATION CO. LTD.-PLANT 2

150th St., Second Industrial City, Dammam 31431, KSA

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

ASTM C612-2014

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).

ENG. MAJED AL SHAMSI

Certification and Quality Control of Products Section's Manager
Dubai Central Laboratory Department-Dubai Municipality



Certificate No: CL16020310
Valid Until: 16/01/2026



Current Issue Date: 17/01/2025
Original Issue Date: 17/01/2016



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL16020310

Certificate Issued To: ARABIAN FIBERGLASS INSULATION CO. LTD. - Plant 2
150th Street, Second Industrial City,
Dammam 31431, Kingdom of Saudi Arabia

Applicable Standard Specification: ASTM C 612: 2014 :Standard Specification for
Fiber Block and Board Thermal Insulation

Applicable Specific Rules: DM-DCLD-RD-DP21-2108 (IC) : Certification of
Mineral Fiber Block and Board Thermal Insulation as
per ASTM C 612-14

S/N	PRODUCT DESCRIPTION	PRODUCT BRAND	PRODUCT DETAILS
1.	Mineral Fiber Batts and Board Thermal Insulation Product Description CFC Free (See Note 4)	AFICO QUIET LINER (AQL)	Type IA with black woven glass fabric (WGF) facing Nominal Density: 16 - 48 kg/m ³ Nominal Thickness: 15 - 50 mm k-value: 0.040 W/m-°K @ 35 degree C mean temperature (See Note 3)

NOTE 1: This document forms an integral part of the Certificate of Product Conformity bearing the same certificate number.

NOTE 2: The above product shall bear the DCLD Conformity Mark.

NOTE 3: Maximum k-value measured at 35°C temperature and 60% relative humidity condition.

NOTE 4: CFC Free as per declaration from the company, in accordance with the 2020 Al Sa'fat – Dubai Green Building

NOTE 5: As applicable, other properties in the product standard specification which were excluded in the specific rules as approved by the certification body authorized personnel are to be verified by the end user of the product (if needed).

Original Issue Date : 17-01-2016

Current Issue Date : 17-01-2025

Valid Until : 16-01-2026



ENG. MAJED AL SHAMSI

CERTIFICATION AND QUALITY CONTROL OF PRODUCTS SECTION'S MANAGER