

# CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality  
hereby attests that the product(s)

## Mineral Fiber Block and Board Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

**ARABIAN FIBERGLASS INSULATION CO. LTD.-PLANT 2**  
**150th St., Second Industrial City, Dammam 31431, KSA**

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

## ASTM C612-2014

Accordingly, DCLD hereby authorizes the above manufacturer  
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN  
Director, Dubai Central Laboratory Department  
Dubai Municipality



Certificate No: CL16020310  
Valid Until: 16/01/2023



Current Issue Date: 17/01/2022  
Original Issue Date: 17/01/2016



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.  
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT  
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME  
SCOPE OF CERTIFICATION  
FOR CERTIFICATE NO. CL16020310

**Certificate Issued To:** ARABIAN FIBERGLASS INSULATION CO. LTD. - Plant 2  
150<sup>th</sup> Street, Second Industrial City, P.O. Box: 1289, Dammam  
31431, Kingdom of Saudi Arabia

**Applicable Standard Specification:** ASTM C 612: 2014 – Standard Specification for Fiber Block and Board Thermal Insulation

**Applicable Specific Rules:** DM-DCLD-RD-DP21-2108 (IC) “Specific Rules for Certification of Mineral Fiber Block and Board Thermal Insulation (ASTM C 612: 2014) Through Factory Assessment”.

| S/N | PRODUCT DESCRIPTION   | PRODUCT BRAND              | PRODUCT DETAILS  |
|-----|---|----------------------------|--|
| 1.  | Mineral Fiber Block and Board Thermal Insulation<br>Product Description<br><br>CFC Free<br>(See Note 4) | AFICO QUIET LINER<br>(AQL) | Type IA with black woven glass fabric (WGF) facing<br>Nominal Density: 16 - 48 kg/m <sup>3</sup><br>Nominal Thickness: 25 - 50 mm<br>k-value: 0.040 W/m-°K<br>(See Note 3) |

*Note 1: This document forms part of the Certificate of Product Conformity bearing the same certificate no.*

*Note 2: The above products shall bear the DCL Conformity Mark (applied on each product or on the packaging).*

*Note 3 Maximum k-value measured at 35°C temperature and 60% relative humidity condition.*

*Note 4: CFC Free as per declaration from the company, in accordance with the 2020 Al Sa'fat – Dubai Green Building System.*

*Original Issue Date: 17 January 2016*

*Current Issue Date: 17 January 2022*

*Valid Until: 16 January 2023*



ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager

Dubai Central Laboratory Department